

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF

File

DATE

4-2-90

DEPARTMENT

Sanplex

Block of sump pump and discharge
to sanitary sewer. Jim Mills
to do work. Dick Hoffman
will call to inspect work

SIGNED

B

1635 W. WALNUT



March 8, 1990

Mr. Guy Mace, President
Semblex
1635 West Walnut
Springfield, Missouri 65806-1643

Dear Mr. Mace:

This letter will confirm our conversation of March 6 concerning the discharge of less than three gallons of Allied Colloids Percol 1737 flocculant to the storm sewer.

The discharge occurred from a test pit located in the north portion of your building where polymer feed equipment is tested. This office confirmed the test pit is tributary to the storm sewer on March 7 when dye was placed in the pit and visually confirmed in the storm sewer. The polymer cleanup appeared to be satisfactory as none was observed in the concrete lined ditch.

It is the direction of this office to connect the test pit and all tributary plumbing fixtures to the sanitary sewer within 45 days of the date of this letter. A permit from the Building Regulations Department will be required before construction is started.

As was explained by Mr. Hoffman, Semblex may wish to apply for a permit from the Missouri Department of Natural Resources to discharge to the storm sewer as it is currently connected. If you choose this option, and the process is started within 45 days of the date of this letter, the previous paragraph will not apply.

If you have any questions please feel free to contact this office at 864-1924.

Yours truly,

Stephen Short
Water Pollution Control Inspector

cc Robert Schaefer, P.E., Supt. of Sanitary Services
 Randy Lyman, Supervisor of Surveillance, Enforcement and Billing
 Harvey Cooper, Building Regulations Department
 file (2)